



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 128**

**Customer**

Facility Name: Hampton Inn & Suites North Huntington

Address: 8441 Country Club Drive  
North Huntingdon, PA 15642

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/9/25

Time: 1:01 PM

Method: Grab

**Sample Final Analysis**

Date: 7/12/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25 10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25 10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25 5:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25 1:01 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25 1:01 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25 1:01 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 128**

**Customer**

Facility Name: Hampton Inn & Suites North Huntington

Address: 8441 Country Club Drive  
North Huntingdon, PA 15642

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/9/25

Time: 1:01 PM

Method: Grab

**Sample Final Analysis**

Date: 7/12/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25 10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25 10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25 5:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25 1:01 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25 1:01 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25 1:01 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor