



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 390

Customer

Facility Name: *Fairfield Inn & Suites*
Address: *1000 University Parkway*
Slippery Rock, PA 16057

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *1/20/26*
Time: *2:50 PM*
Method: *Grab*

Sample Final Analysis

Date: *1/23/26*
Time: *11:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	1/21/26 11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/21/26 11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/20/26 5:30 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	1/21/26 10:30 AM	SL	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	1/20/26 2:50 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	1/20/26 2:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/20/26 2:50 PM	BH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)