# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**S-16**

*Lab#* 124

---

**Customer**

| | | **Sample Collection** | |
|---|---|---|---|
| *Facility Name:* | *Hampton Inn* | *Date:* | *8/12/25* |
| | | *Time:* | 11:25 AM |
| *Address:* | *475 Johnson Rd.* | *Method:* | *Grab* |
| | *Washington, PA 15301* | | |
| | | **Sample Final Analysis** | |
| *Matrix:* | *Recreational Water* | *Date:* | *8/15/25* |
| | | *Time:* | *9:00 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/12/25 | 2:56 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/12/25 | 11:25 AM | GR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/12/25 | 11:25 AM | GR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/12/25 | 11:25 AM | GR | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor

**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

*Lab#  124*

## Customer

| | |
|---|---|
| *Facility Name:* | *Hampton Inn* |
| *Address:* | *475 Johnson Rd.* *Washington, PA 15301* |
| *Matrix:* | *Recreational Water* |
| *Source Type:* | *Pool* |

### Sample Collection

| | |
|---|---|
| *Date:* | *8/12/25* |
| *Time:* | 11:25 AM |
| *Method:* | *Grab* |

### Sample Final Analysis

| | |
|---|---|
| *Date:* | *8/15/25* |
| *Time:* | *9:00 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/12/25 | 2:56 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4  SU | 7.2 - 7.8 SU | 8/12/25 | 11:25 AM | GR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/12/25 | 11:25 AM | GR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/12/25 | 11:25 AM | GR | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor