



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2100

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Chateau Perry*
Address: *951 Perry Highway*
Pittsburgh, PA 15237

Date: 6/16/25
Time: 10:46 AM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Pool*

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25 10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25 10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25 5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25 10:46 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25 10:46 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25 10:46 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2100

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Chateau Perry*
Address: *951 Perry Highway*
Pittsburgh, PA 15237

Date: 6/16/25
Time: 10:46 AM
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Pool*

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25 10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25 10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25 5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25 10:46 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25 10:46 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25 10:46 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor