



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 111

Customer

Facility Name: Greenfield Elementary

Address: 1 Alger St.
Pittsburgh, PA 15207

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 12/8/25

Time: 1:06 PM

Method: Grab

Sample Final Analysis

Date: 12/11/25

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	12/9/25	11:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	12/9/25	11:10 AM	JC	SM 9222B
Standard plate count:	0/ml	A	12/8/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.2 SU	C	12/8/25	1:06 PM	MM	DPD
Chlorine:	4.0 mg/l	B	12/8/25	1:06 PM	MM	DPD
Turbidity:	1 NTU	A	12/8/25	1:06 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)