Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2165

Customer

Facility Name:	*Edgetown Condo*
Address:	*205 Coraopolis Rd.*
	Coraopolis, PA 15108
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/2/25*
Time:	8:15 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/4/25*
Time:	*3:30 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/2/25	8:15 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/2/25	8:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	8:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith
_____
Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

SERVICE

Lab# 2165

Customer

Facility Name:	Edgetown Condo
Address:	205 Coraopolis Rd. Coraopolis, PA 15108
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	7/2/25
Time:	8:15 AM
Method:	Grab

Sample Final Analysis

Date:	7/4/25
Time:	3:30 PM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/2/25	8:15 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/2/25	8:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	8:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor