1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# **275**

Customer		*Sample Collection*	
Facility Name:	*Shady Side Academy*	*Date:*	*5/28/25*
		Time:	11:50 AM
Address:	*423 Fox Chapel Rd*	*Method:*	*Grab*
	Pittsburgh, PA 15221		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*5/31/25*
		Time:	*9:30 AM*
Source Type:	*Pool Deep*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:50 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:50 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:50 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer		*Sample Collection*	
Facility Name:	*Shady Side Academy*	*Date:*	*5/28/25*
		Time:	11:50 AM
Address:	*423 Fox Chapel Rd*	*Method:*	*Grab*
	Pittsburgh, PA 15221		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*5/31/25*
		Time:	*9:30 AM*
Source Type:	*Pool Deep*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:50 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:50 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:50 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor