



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 221

Customer

Facility Name: *Masonic Village*

Address: *1000 Masonic Dr.*
Sewickley, PA 15143

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *11/19/25*

Time: *1:05 PM*

Method: *Grab*

Sample Final Analysis

Date: *11/21/25*

Time: *4:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	11/19/25 5:55 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/19/25 5:55 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/19/25 5:40 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	11/19/25 5:55 PM	SL	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.2 SU	7.2 - 7.8 SU	11/19/25 1:05 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/19/25 1:05 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/19/25 1:05 PM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)