



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 404**

**Customer**

Facility Name: Wilfred R.Cameron Wellness Center

Address: 240 Wellness Way  
Washington, PA 15301

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 10/20/25

Time: 9:28 AM

Method: Grab

**Sample Final Analysis**

Date: 10/23/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 10/21/25   | 9:30 AM   | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 10/21/25   | 9:30 AM   | JC      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 10/20/25   | 2:50 PM   | SL      | SM 9215B |

| Additional Analysis | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|---------------------|----------|-----------------|------------|-----------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls        | 10/21/25   | 10:30 AM  | JC      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time        | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 10/20/25 9:28 AM | GR      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 10/20/25 9:28 AM | GR      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 10/20/25 9:28 AM | GR      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor