



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 073

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Drive
West Homestead, PA 15120

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 9:10 AM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	9:10 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	9:10 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	9:10 AM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 073

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Drive
West Homestead, PA 15120

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 9:10 AM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	9:10 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	9:10 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	9:10 AM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor