



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 213

Customer

Facility Name: Langley High School

Address: 2940 Sheradan Blvd.
Pittsburgh, PA 15204

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 12/9/25

Time: 9:04 AM

Method: Grab

Sample Final Analysis

Date: 12/12/25

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	12/10/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	12/10/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	A	12/9/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	12/9/25	9:04 AM	MM	DPD
Chlorine:	3.0 mg/l	A	12/9/25	9:04 AM	MM	DPD
Turbidity:	1 NTU	A	12/9/25	9:04 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)