



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2569

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: West Pointe Apt
Address: 3000 Westpointe Drive
Pittsburgh, PA 15205

Date: 8/12/25
Time: 7:30 AM
Method: Grab

Sample Final Analysis

Matrix: 3000 Westpointe Drive
Source Type: Pool

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/12/25 7:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25 7:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25 7:30 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2569

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: West Pointe Apt
Address: 3000 Westpointe Drive
Pittsburgh, PA 15205

Date: 8/12/25
Time: 7:30 AM
Method: Grab

Sample Final Analysis

Matrix: 3000 Westpointe Drive
Source Type: Pool

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/12/25 7:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/12/25 7:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25 7:30 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor