



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2233

Customer

Facility Name: Green Oaks C.C.

Address: 5741 3rd Street
Verona, PA 15147

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/5/25

Time: 1:40 PM

Method: Grab

Sample Final Analysis

Date: 8/8/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/5/25	1:40 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:40 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:40 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2233

Customer

Facility Name: Green Oaks C.C.

Address: 5741 3rd Street
Verona, PA 15147

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/5/25

Time: 1:40 PM

Method: Grab

Sample Final Analysis

Date: 8/8/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/5/25	1:40 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	1:40 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	1:40 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor