

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2111

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Clearview Swim Club Date: 6/2/25

Address: 5430 Martin St. Time: 11:27 AM Method: Grab

Aliquippa, PA 15001

Matrix: Recreational Water Sample Final Analysis

Date: 6/5/25

Source Type: Pool Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Analyst Incubation Date/Time** Method 6/3/25 11:30 AM Escherichia Coli: Absent Absent EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 11:30 AM EB SM 9222B Standard plate count: 0/ml 200/ml 6/2/25 6:45 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/2/25 | 11:27 AM | АН | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 6/2/25 | 11:27 AM | АН | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/2/25 | 11:27 AM | АН | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2111

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Clearview Swim Club Date: 6/2/25

Address: 5430 Martin St. Time: 11:27 AM Method: Grab

Aliquippa, PA 15001

Matrix: Recreational Water Sample Final Analysis

Date: 6/5/25

Source Type: Pool Time: 9:30 AM
Analyst: AS

Accredited Analysis Results Reporting limit **Analyst Incubation Date/Time** Method 6/3/25 11:30 AM Escherichia Coli: Absent Absent EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 11:30 AM EB SM 9222B Standard plate count: 0/ml 200/ml 6/2/25 6:45 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 6/2/25 | 11:27 AM | АН | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 6/2/25 | 11:27 AM | АН | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/2/25 | 11:27 AM | АН | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor