

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2037

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Belmont Ridge

Address: 1100 Belmont Blvd.

Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/4/25 Time: 7:33 AM

Method: Grab

Sample Final Analysis

Date: 8/7/25 Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	АН	SM 9222B
	o, 10011110	_,	0, 0, =0	0.20 /		· · · · · · · · · · · · · · · · · · ·
Standard plate count:	0/ml	200/ml	8/4/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	nit Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	7:33 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	7:33 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	7:33 AM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2037

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Belmont Ridge

Address: 1100 Belmont Blvd.

Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/4/25 Time: 7:33 AM

Method: Grab

Sample Final Analysis

Date: 8/7/25 Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:20 AM	АН	SM 9222B
	o, 10011110	_,	0, 0, =0	0.20 /		· · · · · · · · · · · · · · · · · · ·
Standard plate count:	0/ml	200/ml	8/4/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	nit Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/4/25	7:33 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	7:33 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	7:33 AM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)