



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 2094**

**Customer**

Facility Name: Chapel Valley Swim Club

Address: 118 Bainbridge Drive  
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Large Pool

**Sample Collection**

Date: 8/11/25

Time: 12:26 PM

Method: Grab

**Sample Final Analysis**

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	8/11/25	12:26 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	12:26 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	12:26 PM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 2094**

**Customer**

Facility Name: Chapel Valley Swim Club

Address: 118 Bainbridge Drive  
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Large Pool

**Sample Collection**

Date: 8/11/25

Time: 12:26 PM

Method: Grab

**Sample Final Analysis**

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	8/11/25	12:26 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	12:26 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	12:26 PM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor