



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 117

Customer

Facility Name: Hampton Inn
Address: 1247 Smallman St.
Pittsburgh, PA 15222

Sample Collection

Date: 11/18/25
Time: 10:45 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 11/21/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|-------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 11/19/25 10:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 11/19/25 10:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 11/18/25 4:04 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 11/19/25 10:20 AM | AS | SM 9230C |
|---------------------|----------|----------|-------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|-------------------|----|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 11/18/25 10:45 AM | BH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 11/18/25 10:45 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/18/25 10:45 AM | BH | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)