

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

Laboratory Analysis Report

C-11

Lab ID No. 02-04041

Lab# 462

Customer

Facility Name: Rivers Club

Address:

301 Grant St

Pittsburgh, PA 15212

Matrix:

Source Type:

Recreational Water

Pool

Sample Collection Date: 7/8/25

Time:

11:30 AM

Method: Grab

Sample Final Analysis

Date:

7/11/25 9:00 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/8/25	4:30 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.6 SU	7.2 - 7.8 SU	7/8/25	11:30 AM	LM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:30 AM	LM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:30 AM	LM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

Laboratory Analysis Report

C-11

Lab ID No. 02-04041

Lab# 462

Customer

Facility Name: Rivers Club

Address:

301 Grant St

Pittsburgh, PA 15212

Matrix:

Source Type:

Recreational Water

Pool

Sample Collection Date: 7/8/25

Time:

11:30 AM

Method: Grab

Sample Final Analysis

Date:

7/11/25 9:00 AM

Time: Analyst:

AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/8/25	4:30 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.6 SU	7.2 - 7.8 SU	7/8/25	11:30 AM	LM	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:30 AM	LM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:30 AM	LM	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith Andre Smith, Lead Supervisor