



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2719**

**Customer**

Facility Name: Meeder Flats  
Address: 1000 Strand Road  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Spa

**Sample Collection**

Date: 6/2/25  
Time: 1:23 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/5/25  
Time: 9:30 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/3/25 9:15 AM       | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/3/25 9:15 AM       | EB      | SM 9222B |
| Standard plate count: | 80/ml    | 200/ml          | 6/2/25 3:17 PM       | AH      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 6/3/25 11:30 AM      | AH      | SM 9230C |
| Field Analysis        | Results  | Reporting limit | Date/Time            | Analyst | Method   |
| pH:                   | 7.6 SU   | 7.2 - 7.8 SU    | 6/2/25 1:23 PM       | ZR      | DPD      |
| Chlorine:             | 0.0 mg/l | 1.0 - 5.0 mg/l  | 6/2/25 1:23 PM       | ZR      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 6/2/25 1:23 PM       | ZR      | Visual   |

**Sample comments**

*Anaë Smith*

( When exceeding reporting limit pool or spa is unfit)



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2719**

**Customer**

Facility Name: Meeder Flats  
Address: 1000 Strand Road  
Cranberry, PA 16066

Matrix: Recreational Water  
Source Type: Spa

**Sample Collection**

Date: 6/2/25  
Time: 1:23 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/5/25  
Time: 9:30 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/3/25 9:15 AM       | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/3/25 9:15 AM       | EB      | SM 9222B |
| Standard plate count: | 80/ml    | 200/ml          | 6/2/25 3:17 PM       | AH      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 6/3/25 11:30 AM      | AH      | SM 9230C |
| Field Analysis        | Results  | Reporting limit | Date/Time            | Analyst | Method   |
| pH:                   | 7.6 SU   | 7.2 - 7.8 SU    | 6/2/25 1:23 PM       | ZR      | DPD      |
| Chlorine:             | 0.0 mg/l | 1.0 - 5.0 mg/l  | 6/2/25 1:23 PM       | ZR      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 6/2/25 1:23 PM       | ZR      | Visual   |

**Sample comments**

*Anaë Smith*

( When exceeding reporting limit pool or spa is unfit)