



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2107

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *City Vista Apts* *Date:* *6/30/25*
Address: *325 Elizabeth Dr.* *Time:* *3:00 PM*
Pittsburgh, PA 15220 *Method:* *Grab*

Sample Final Analysis

Matrix: *Recreational Water* *Date:* *7/3/25*
Source Type: *Pool* *Time:* *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25	3:00 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/30/25	3:00 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	3:00 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2107

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *City Vista Apts* *Date:* *6/30/25*
Address: *325 Elizabeth Dr.* *Time:* *3:00 PM*
Pittsburgh, PA 15220 *Method:* *Grab*

Sample Final Analysis

Matrix: *Recreational Water* *Date:* *7/3/25*
Source Type: *Pool* *Time:* *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25 11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25 11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25 6:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25 3:00 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/30/25 3:00 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25 3:00 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor