



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2315**

**Customer**

Facility Name: *Laurel Mountain*

Address: *421 Weaver Mill Road*  
*Rector, PA 15677*

Matrix: *Recreational Water*

Source Type: *Slide Pool*

**Sample Collection**

Date: *7/7/25*

Time: *12:30 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/7/25	12:30 PM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/7/25	12:30 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:30 PM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2315**

**Customer**

Facility Name: Laurel Mountain

Address: 421 Weaver Mill Road  
Rector, PA 15677

Matrix: Recreational Water

Source Type: Slide Pool

**Sample Collection**

Date: 7/7/25

Time: 12:30 PM

Method: Grab

**Sample Final Analysis**

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/7/25	12:30 PM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/7/25	12:30 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:30 PM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor