



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 377

Customer

Facility Name: Drury Hotel
Address: 745 Grant St.
Pittsburgh, PA 15219

Sample Collection

Date: 1/27/26
Time: 10:25 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 1/30/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/28/26	10:30 AM	JC
Total coliforms:	0/100mls	2/100mls	1/28/26	10:30 AM	JC
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	AS

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/28/26	11:30 AM	JC

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/27/26	10:25 AM	BH
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	1/27/26	10:25 AM	BH
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	10:25 AM	BH

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)