



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2491

Customer

Facility Name: Sheraton Inn

Address: 1160 Thorn Run Road
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/18/25

Time: 7:49 AM

Method: Grab

Sample Final Analysis

Date: 8/21/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	11:00 AM	EB	SM 9222B
Standard plate count:	180/ml	200/ml	8/18/25	6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/18/25	7:49 AM	AH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/18/25	7:49 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	7:49 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor