Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 465

Customer

Facility Name: *Towers Pool*

Address: *1206 Bluff St.*
Pittsburgh, PA 15282

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *5/28/25*
Time: 11:50 AM
Method: *Grab*

Sample Final Analysis

Date: *5/31/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	11:50 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:50 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 465

Customer

Facility Name: *Towers Pool*

Address: *1206 Bluff St.*
Pittsburgh, PA 15282

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *5/28/25*
Time: 11:50 AM
Method: *Grab*

Sample Final Analysis

Date: *5/31/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	11:50 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:50 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:50 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith

Andre Smith, Lead Supervisor