



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 453

Customer

Facility Name: *Fairfield Inn Butler*

Address: *200 Fairfield Ln
Butler, PA 16001*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *10/13/25*

Time: *3:25 PM*

Method: *Grab*

Sample Final Analysis

Date: *10/16/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/14/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/14/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/13/25	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	10/13/25	3:25 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/13/25	3:25 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/13/25	3:25 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor