

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2749

Customer	Sample Collection					
Facility Name:	Executive Ho	use		Date:	6/17/25	
				Time:	10:50 AM	
Address:	800 Beau Dr.			Method:	Grab	
	Washington, I	PA 15301				
A.A. C.	D	147-7		Sample Final Analysis		
Matrix: Recreational Water				Date: 6/20/25		
Cauraa Turaa	Dool			Time:	9:00 AN	
Source Type:	Pool			Analyst:	AS	>
Accredited Analysis	Results	Reporting limit	Incubatio	n Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:00 AM	EB	SM 9222G
Total coliforms:	2/100mls	2/100mls	6/18/25	10:00 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	D	ate/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	10:50 AM	GR	DPD
ρι ι.	0.0 00	1.2 - 1.0 00	0/11/20	10.50 AW	OIX	טוט
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/17/25	10:50 AM	GR	DPD

6/17/25

1 - 2 NTU

Sample comments

Turbidity:

(When exceeding reporting limit pool or spa is unfit)

1 NTU

andre Smith

Andre Smith, Lead Supervisor

10:50 AM

GR

Visual



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2749

Customer	Sample Collection					
Facility Name:	Executive Ho	use		Date:	6/17/25	
				Time:	10:50 AM	
Address:	800 Beau Dr.			Method:	Grab	
	Washington, I	PA 15301				
A.A. C.	D	147-7		Sample Final Analysis		
Matrix: Recreational Water				Date: 6/20/25		
Cauraa Turaa	Dool			Time:	9:00 AN	
Source Type:	Pool			Analyst:	AS	>
Accredited Analysis	Results	Reporting limit	Incubatio	n Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:00 AM	EB	SM 9222G
Total coliforms:	2/100mls	2/100mls	6/18/25	10:00 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	D	ate/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	10:50 AM	GR	DPD
ρι ι.	0.0 00	1.2 - 1.0 00	0/11/20	10.50 AW	OIX	טוט
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/17/25	10:50 AM	GR	DPD

6/17/25

1 - 2 NTU

Sample comments

Turbidity:

(When exceeding reporting limit pool or spa is unfit)

1 NTU

andre Smith

Andre Smith, Lead Supervisor

10:50 AM

GR

Visual