



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**W-13**

**Lab# 2086**

**Customer**

**Facility Name:** Centennial Point  
**Address:** 423 Patriot Dr.  
Carnegie, PA 15106

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 7/22/25  
**Time:** 7:52 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/22/25	7:52 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	7:52 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	7:52 AM	AH	Visual

**Sample comments**

\_\_\_\_\_  
Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

\_\_\_\_\_  
Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**W-13**

**Lab# 2086**

**Customer**

Facility Name: Centennial Point  
Address: 423 Patriot Dr.  
Carnegie, PA 15106

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 7/22/25  
Time: 7:52 AM  
Method: Grab

**Sample Final Analysis**

Date: 7/25/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/22/25	7:52 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	7:52 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	7:52 AM	AH	Visual

**Sample comments**

\_\_\_\_\_  
Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

\_\_\_\_\_  
Andre Smith, Lead Supervisor