



Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service**Lab# 425****Customer**

Facility Name: Chatham University
Address: 1 Woodland Rd.
Pittsburgh, PA 15232

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 1/12/26
Time: 9:45 AM
Method: Grab

Sample Final Analysis

Date: 1/15/26
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 1/13/26 | 9:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/13/26 | 9:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/12/26 | 4:45 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 1/12/26 | 9:45 AM | MB | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 1/12/26 | 9:45 AM | MB | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/12/26 | 9:45 AM | MB | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor