



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2472

Customer

Facility Name: Scott Twp.
Address: 301 Lindsay Road
Carnegie, PA 15106

Sample Collection

Date: 7/7/25
Time: 1:06 PM
Method: Grab

Matrix: Recreational Water
Source Type: Deep End

Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	1:06 PM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:06 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:06 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2472

Customer

Facility Name: Scott Twp.
Address: 301 Lindsay Road
Carnegie, PA 15106

Sample Collection

Date: 7/7/25
Time: 1:06 PM
Method: Grab

Matrix: Recreational Water
Source Type: Deep End

Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	1:06 PM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:06 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:06 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor