



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 445**

**Customer**

**Facility Name:** Highpoint Fitness  
**Address:** 1000 Higbee Dr.  
Bethel Park, PA 15102

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 2/3/26  
**Time:** 11:59 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 2/6/26  
**Time:** 11:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/4/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/4/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/3/26	5:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12:00 AM	11:00 AM	SL	SM 9213C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/3/26	11:59 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/3/26	11:59 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/3/26	11:59 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor