



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2752

**Customer**

Facility Name: Scott Twp.  
Address: 301 Lindsay Road  
Carnegie, PA 15106

Matrix: Recreational Water  
Source Type: Splash Pad

**Sample Collection**

Date: 5/27/25  
Time: 1:44 PM  
Method: Grab

**Sample Final Analysis**

Date: 5/30/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	1:44 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	1:44 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	1:44 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2752

**Customer**

Facility Name: Scott Twp.  
Address: 301 Lindsay Road  
Carnegie, PA 15106

Matrix: Recreational Water  
Source Type: Splash Pad

**Sample Collection**

Date: 5/27/25  
Time: 1:44 PM  
Method: Grab

**Sample Final Analysis**

Date: 5/30/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/27/25	1:44 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/27/25	1:44 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	1:44 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor