



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 311**

**Customer**

**Facility Name:** UPMC Lemieux Sports Complex

**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 8/26/25

**Time:** 11:35 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 8/29/25

**Time:** 10:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	8/27/25 11:00 AM	AS	SM 9222G
-------------------	--------	--------	------------------	----	----------

Total coliforms:	0/100mls	2/100mls	8/27/25 11:00 AM	AS	SM 9222B
------------------	----------	----------	------------------	----	----------

Standard plate count:	0/ml	200/ml	8/26/25 5:30 PM	AS	SM 9215B
-----------------------	------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	8/27/25 12:10 PM	PS	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.5 SU	7.2 - 7.8 SU	8/26/25 11:35 AM	JR	DPD
-----	--------	--------------	------------------	----	-----

Chlorine:	4.5 mg/l	1.0 - 5.0 mg/l	8/26/25 11:35 AM	JR	DPD
-----------	----------	----------------	------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	8/26/25 11:35 AM	JR	Visual
------------	-------	-----------	------------------	----	--------

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor