



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2552

**Customer**

Facility Name: Village of Neville Park

Address: 1001 Grey Fox Circle  
Collier Twp, PA 15017

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 5/27/25

Time: 10:43 AM

Method: Grab

**Sample Final Analysis**

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	AH
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	AH
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:43 AM	AF
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:43 AM	AF
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:43 AM	AF

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andrea Smith



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2552

**Customer**

Facility Name: Village of Neville Park

Address: 1001 Grey Fox Circle  
Collier Twp, PA 15017

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 5/27/25

Time: 10:43 AM

Method: Grab

**Sample Final Analysis**

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	AH
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	AH
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:43 AM	AF
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:43 AM	AF
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:43 AM	AF

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andrea Smith