



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 160**

**Customer**

**Facility Name:** Holiday Inn Express  
**Address:** 810 Highland Meadow Dr.  
Washington, PA 15301

**Sample Collection**

**Date:** 2/16/26  
**Time:** 9:45 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 2/18/26  
**Time:** 10:30 AM  
**Analyst:** AS

**Source Type:** Spa

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	2/17/26	10:00 AM	SL	SM 9222G
-------------------	--------	--------	---------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	2/17/26	10:00 AM	SL	SM 9222B
------------------	----------	----------	---------	----------	----	----------

Standard plate count:	0/ml	200/ml	2/16/26	3:40 PM	SL	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	2/17/26	Total coliforms:	SL	SM 9230C
---------------------	----------	----------	---------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	2/16/26	9:45 AM	GR	DPD
-----	--------	--------------	---------	---------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/16/26	9:45 AM	GR	DPD
-----------	----------	----------------	---------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	2/16/26	9:45 AM	GR	Visual
------------	-------	-----------	---------	---------	----	--------

**Sample comments**

*Andre Smith*

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)