



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2112

Customer

Facility Name: Clearview Swim Club

Address: 5430 Martin St.
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Baby

Sample Collection

Date: 7/14/25

Time: 10:08 AM

Method: Grab

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	10:08 AM	AH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:08 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:08 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2112

Customer

Facility Name: Clearview Swim Club

Address: 5430 Martin St.
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Baby

Sample Collection

Date: 7/14/25

Time: 10:08 AM

Method: Grab

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	7/14/25	10:08 AM	AH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:08 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:08 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor