



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2645

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 6/16/25
Time: 1:15 PM
Method: Grab

Sample Final Analysis

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Facility Name: Pennwood Square
Address: 601 A Hay St
Pittsburgh, PA 15221

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	9:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	9:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/16/25	1:15 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	1:15 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:15 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2645

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Pennwood Square

Date: 6/16/25

Address: 601 A Hay St
Pittsburgh, PA 15221

Time: 1:15 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/19/25

Source Type: Pool

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	9:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	9:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/16/25	1:15 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	1:15 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:15 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor