



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2141**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Crane Village*

*Date: 6/9/25*

*Address: 651 Oaklynn Court*  
*Pittsburgh, PA 15220*

*Time: 2:15 PM*

*Method: Grab*

*Matrix: Recreational Water*

**Sample Final Analysis**

*Date: 6/12/25*

*Source Type: Pool*

*Time: 9:30 AM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/10/25	10:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	EB	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	2:15 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/9/25	2:15 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	2:15 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2141**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Crane Village*

*Date: 6/9/25*

*Address: 651 Oaklynn Court*  
*Pittsburgh, PA 15220*

*Time: 2:15 PM*

*Method: Grab*

*Matrix: Recreational Water*

**Sample Final Analysis**

*Source Type: Pool*

*Date: 6/12/25*

*Time: 9:30 AM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/10/25	10:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	EB	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	2:15 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/9/25	2:15 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	2:15 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor