



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2565

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Waterfront*

Date: *6/23/25*

Address: *611 E. Waterfront Dr.*
Munhall, PA 15120

Time: *10:40 AM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *6/26/25*

Source Type: *Pool*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	6:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/23/25	10:40 AM	DW	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/23/25	10:40 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	10:40 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2565

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Waterfront*

Date: 6/23/25

Address: 611 E. Waterfront Dr.
Munhall, PA 15120

Time: 10:40 AM

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: 6/26/25

Source Type: *Pool*

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	6:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/23/25	10:40 AM	DW	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/23/25	10:40 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	10:40 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor