1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab# 047

Customer		***Sample Collection***	
Facility Name:	*Chartiers Valley H.S.*	*Date:*	5/27/25
		Time:	10:52 AM
Address:	*50 Thoms Run Road*	*Method:*	*Grab*
	Bridgeville, PA 15017		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	5/30/25
		Time:	9:00 AM
Source Type:	*Deep End*	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:52 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:52 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:52 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab# 047

Customer		*Sample Collection*	
Facility Name:	*Chartiers Valley H.S.*	*Date:*	*5/27/25*
		Time:	10:52 AM
Address:	*50 Thoms Run Road*	*Method:*	*Grab*
	Bridgeville, PA 15017		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*5/30/25*
		Time:	*9:00 AM*
Source Type:	*Deep End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	10:52 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/27/25	10:52 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	10:52 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor