

**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 2**

**Lab# 2129**

**Customer**

American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Community Swim Club

**Sample Collection**

Date: 7/29/25

Address: 106 Aqua Drive  
Pittsburgh, PA 15238

Time: 1:50 PM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 8/1/25

Source Type: Shallow End

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	EB	SM 9215B


Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/29/25	1:50 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/29/25	1:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	1:50 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 2**

**Lab# 2129**

**Customer**

American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Community Swim Club

**Sample Collection**

Date: 7/29/25

Address: 106 Aqua Drive  
Pittsburgh, PA 15238

Time: 1:50 PM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 8/1/25

Source Type: Shallow End

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/29/25	1:50 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/29/25	1:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	1:50 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor