



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 386

Customer

Facility Name: *Residence Inn Cranberry*

Address: *1308 Freedom RDd.
Cranberry, PA 16066*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *2/4/26*

Time: *12:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *2/6/26*

Time: *4:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/4/26	3:45 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/4/26	3:45 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/3/26	3:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	2/4/26	12:15 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/4/26	12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/4/26	12:15 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor