



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 232

Customer

Facility Name: Moon Area High School

Address: 8353 University Blvd.
Coraopolis, PA 15108

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 11/3/25

Time: 9:32 AM

Method: Grab

Sample Final Analysis

Date: 11/6/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 11/4/25 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 11/4/25 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 11/3/25 | 5:30 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 11/3/25 | 9:32 AM | AMH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 11/3/25 | 9:32 AM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/3/25 | 9:32 AM | AMH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor