

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM** 3

Lab# 2525

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Torrent of Upper St. Clair

Address: 2565 Boyce Plaza Rd.

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/21/25

 Time:
 2:06 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/24/25

 Time:
 10:00 AM

 Analyst:
 AS

Accredited Analysis	Results Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	2:06 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/21/25	2:06 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	2:06 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM** 3

Lab# 2525

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Torrent of Upper St. Clair

Address: 2565 Boyce Plaza Rd.

Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/21/25

 Time:
 2:06 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/24/25

 Time:
 10:00 AM

 Analyst:
 AS

Accredited Analysis	Results Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/21/25	2:06 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/21/25	2:06 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	2:06 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor