



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 173

Customer

Facility Name: Hopewell High School

Address: 1215 Longvue Ave.
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/8/25

Time: 12:04 PM

Method: Grab

Sample Final Analysis

Date: 9/11/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/9/25 9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/9/25 9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/8/25 5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/8/25 12:04 PM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/8/25 12:04 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/8/25 12:04 PM	AMH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor