



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2134**

**Customer**

Facility Name: Crafton Borough Pool

Address: 117 W. Steuben St.  
Crafton, PA 15205

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 8/13/25

Time: 9:15 AM

Method: Grab

**Sample Final Analysis**

Date: 8/15/25

Time: 4:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	3:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/13/25	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/13/25	9:15 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/13/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/13/25	9:15 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 2134**

**Customer**

Facility Name: Crafton Borough Pool

Address: 117 W. Steuben St.  
Crafton, PA 15205

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 8/13/25

Time: 9:15 AM

Method: Grab

**Sample Final Analysis**

Date: 8/15/25

Time: 4:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	3:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/13/25	3:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/13/25	9:15 AM	VH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/13/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/13/25	9:15 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor