



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**W-10**

**Lab# 020**

**Customer**

**Facility Name:** Beaver Area HS  
**Address:** Gypsy Glen  
Beaver, PA 15009

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 8/25/25  
**Time:** 12:05 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/28/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25	10:15 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	10:15 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	5:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/25/25	12:05 PM	AMH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/25/25	12:05 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	12:05 PM	AMH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor