



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 452

**Customer**

Facility Name: Doubletree Cranberry

**Sample Collection**

Date: 6/16/25

Time: 9:32 AM

Method: Grab

Address: 910 Sheraton Dr  
Mars, PA 16046

**Sample Final Analysis**

Date: 6/19/25

Time: 10:00 AM

Analyst: 1/0/00

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	9:20 AM	EB
Total coliforms:	0/100mls	2/100mls	6/17/25	9:20 AM	EB
Standard plate count:	570/ml	200/ml	6/16/25	2:46 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/16/25	9:32 AM	ZR
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	9:32 AM	ZR
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	9:32 AM	ZR

**Sample comments**

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 452

**Customer**

Facility Name: Doubletree Cranberry

**Sample Collection**

Date: 6/16/25

Time: 9:32 AM

Method: Grab

Address: 910 Sheraton Dr  
Mars, PA 16046

**Sample Final Analysis**

Date: 6/19/25

Time: 10:00 AM

Analyst: 1/0/00

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	9:20 AM	EB
Total coliforms:	0/100mls	2/100mls	6/17/25	9:20 AM	EB
Standard plate count:	570/ml	200/ml	6/16/25	2:46 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/16/25	9:32 AM	ZR
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	9:32 AM	ZR
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	9:32 AM	ZR

**Sample comments**

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".