



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041
Service

Lab# 380

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	PPG Paints Arena	Date:	2/16/26		
Address:	1001 Fifth Ave Pittsburgh, PA 15219	Time:	11:45 AM		
Matrix:		Method:	Grab		
Source Type:		<u>Sample Final Analysis</u>			
Recreational Water		Date:	2/18/26		
Therapy Spa		Time:	10:30 AM		
		Analyst:	AS		
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/17/26	10:00 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	2/17/26	10:00 AM	SL SM 9222B
Standard plate count:	100/ml	200/ml	2/16/26	5:08 PM	SL SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	2/17/26	12:00 PM	SL SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	2/16/26	11:45 AM	AG DPD
Chlorine:	4.6 mg/l	1.0 - 5.0 mg/l	2/16/26	11:45 AM	AG DPD
Turbidity:	1 NTU	1 - 2 NTU	2/16/26	11:45 AM	AG Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor