



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2065**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/25/25*  
*Time: 12:38 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/28/25*  
*Time: 9:00 AM*  
*Analyst: AS*

*Facility Name: Bryn Mawr*  
*Address: 100 Bryn Mawr Court*  
*Pittsburgh, PA 15221*

*Matrix: Recreational Water*  
*Source Type: Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25	9:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	9:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	3:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/25/25	12:38 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/25/25	12:38 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	12:38 PM	EH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor