



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 414

Customer

Facility Name: *Townplace Suites Airport*

Address: *1006 Sutherland Dr.*
Pittsburgh, PA 15205

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *6/10/25*

Time: *10:15 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/13/25*

Time: *9:30 AM*

Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/11/25	11:40 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	10:15 AM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/10/25	10:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:15 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 414

Customer

Facility Name: *Townplace Suites Airport*

Address: *1006 Sutherland Dr.*
Pittsburgh, PA 15205

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *6/10/25*

Time: *10:15 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/13/25*

Time: *9:30 AM*

Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	3:12 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/11/25	11:40 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	10:15 AM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/10/25	10:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	10:15 AM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor